

The results listed on this page are from residential homes in Chicago that have volunteered to have their water tested for lead as part of a research study. The data that is shown below is quality controlled. The study is ongoing, and the results below are a small portion of the large sample population necessary for statistical evaluation. The data below will be further reviewed prior to inclusion in statistical evaluation. The results are anonymized to the block level, so the complete address of each home is not posted. In cases where a sample tests over 15 parts per billion (the action limit set by the EPA), the Department of Water Management will contact the homeowner to discuss the results and schedule a time to resample the water and inspect the home's plumbing and electrical wiring to better evaluate possible causes. All results are shown in PPB (Parts per Billion). In cases where multiple homes on the same block have results, the location is further amended as "Site 1", "Site 2", etc.

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
9/28/2016	100XX S. Eggleston Ave.	1.9	1.4	1.5	1.3		
9/28/2016	101XX S. Eggleston Ave.	1.9	1.5	1.8	0.8		
1/10/2017	101XX S. Eggleston Ave.	1.8	1.1	1.1	0.7	0.7	
2/8/2017	101XX S. Eggleston Ave.	2.0	1.1	1.2	0.6		
3/7/2017	101XX S. Eggleston Ave.	2.1	1.0	1.0	0.7		
4/4/2017	101XX S. Eggleston Ave.	1.7	1.1	1.1	0.8		
5/9/2017	101XX S. Eggleston Ave.	2.1	1.5	1.4	1.2		
6/6/2017	101XX S. Eggleston Ave.	1.4	1.0	1.1	0.9		
6/20/2017	101XX S. Racine Ave.	3.1	4.7	4.4	2.7		
9/28/2016	102XX S. Eggleston Ave. <b>Site 1</b>	3.8	7.6	10	4.7		
1/10/2017	102XX S. Eggleston Ave. <b>Site 1</b>	4.1	4.2	7.9	1.8		
10/12/2016	102XX S. Eggleston Ave. <b>Site 2</b>	5.5	8.0	13	5.3		
1/12/2017	102XX S. Eggleston Ave. <b>Site 2</b>	4.8	4.8	8.4	2.3		
9/29/2016	102XX S. Eggleston Ave. <b>Site 3</b>	1.9	1.0	0.9	0.6		
1/11/2017	102XX S. Eggleston Ave. <b>Site 3</b>	1.8	1.9	1.9	0.8		
9/15/2016	103XX S. Racine Ave.	5.5	5.0	18	4.5		
10/8/2016	103XX S. Racine Ave.	See Follow-Up Sequential Sampling Table for Results					
9/15/2016	10XX W. 103rd St.	6.4	2.6	4.0	2.0		
2/8/2017	104XX S. Artesian Ave.	3.7	2.0	3.3	1.3	1.2	
3/8/2017	104XX S. Artesian Ave.	3.2	3.6	3.9	1.2		
7/28/2017	105XX S. Racine Ave.	4.4	3.9	12	8.4		
8/8/2017	105XX S. Racine Ave.	4.3	6.8	7.6	4.3		
6/20/2017	106XX S. Racine Ave.	1.2	2.6	2.5	2.3		
6/23/2017	107XX S. Ave. N	5.0	14.0	12.0	3.1		
7/21/2017	107XX S. Ave. N	5.8	23.0	15.0	4.4		
9/6/2017	107XX S. Ave. N	See Follow-Up Sequential Sampling Table for Results					
4/4/2017	11XX W. 104th St.	4.4	2.6	2.3	0.6		
4/14/2017	11XX W. 104th St.	1.2	1.0	1.1	0.7		
8/23/2017	11XX W. 19th Pl.	2.2	4.2	6.2	2.7		
8/25/2016	11XX E. 81st St. <b>Site 1</b>	2.0	2.2	1.8	1.2	1.2	
12/15/2016	11XX E. 81st St. <b>Site 1</b>	3.8	3.3	13	1.0		
8/25/2016	11XX E. 81st St. <b>Site 2</b>	1.2	1.9	2.9	0.9		
12/15/2016	11XX E. 81st St. <b>Site 2</b>	0.8	1.2	2.5	0.4	0.3	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
6/20/2017	11XX W. 102nd St.	3.1	3.0	8.1	1.8	1.8
4/14/2017	12XX W. 97th St. <b>Site 1</b>	1.0	2.6	3.3	1.2	
4/14/2017	12XX W. 97th St. <b>Site 2</b>	2.2	2.7	4.2	0.8	
4/17/2017	12XX W. 97th St. <b>Site 3</b>	5.1	11	11	7.4	
4/13/2017	12XX W. 97th St. <b>Site 4</b>	1.1	1.5	1.7	0.9	
5/12/2017	12XX W. 97th St. <b>Site 5</b>	0.9	0.9	0.9	0.7	
4/21/2017	12XX W. 97th Pl. <b>Site 1</b>	1.7	2.2	2.7	1.3	
4/13/2017	12XX W. 97th Pl. <b>Site 2</b>	4.3	6.5	6.5	1.4	
6/1/2017	12XX W. 97th St. <b>Site 6</b>	0.8	0.8	1.1	0.6	
4/21/2017	12XX W. 97th Pl. <b>Site 3</b>	2.0	2.5	2.6	1.1	
4/14/2017	12XX W. 97th St. <b>Site 7</b>	4.3	4.0	3.9	1.4	
4/14/2017	12XX W. 97th Pl. <b>Site 5</b>	1.2	1.2	2.5	0.7	
4/14/2017	13XX W. 97th St. <b>Site 1</b>	2.5	2.2	2.3	1.2	
4/13/2017	13XX W. 97th St. <b>Site 2</b>	7.2	4.5	4.3	1.7	
4/14/2017	13XX W. 97th St. <b>Site 3</b>	1.4	1.6	4.2	0.9	
4/14/2017	13XX W. 97th St. <b>Site 4</b>	1.5	1.2	1.3	0.9	
4/14/2017	13XX W. 97th St. <b>Site 5</b>	2.6	4.9	4.8	2.4	
4/19/2017	13XX W. 97th Pl.	2.0	1.5	1.6	1.0	
4/17/2017	14XX W. Touhy Ave.	0.9	3.3	6.4	0.3	
5/8/2017	14XX W. Touhy Ave.	1.8	5.8	4.5	0.5	
10/26/2016	1XX W. 70th St. <b>Site 1</b>	1.6	1.8	1.9	0.7	
10/25/2016	15XX S. St. Louis Ave.	<0.3	<0.3	<0.3	<0.3	
5/25/2017	15XX S. St. Louis Ave.	<0.3	<0.3	<0.3	<0.3	
10/26/2016	1XX W. 70th St. <b>Site 2</b>	0.9	0.8	1.5	0.6	
11/22/2016	16XX W. 37th St.	3.2	6.1	8.8	1.9	
6/23/2017	18XX W. 34th St. <b>Site 1</b>	7.7	5.9	8.4	1.9	
6/23/2017	18XX W. 34th St. <b>Site 3</b>	1.8	3.5	4.2	2.3	
6/23/2017	18XX W. 34th St. <b>Site 4</b>	3.3	3.5	5.9	2.3	
6/23/2017	18XX W. 34th St. <b>Site 5</b>	2.2	1.7	1.9	0.9	
6/23/2017	18XX W. 34th St. <b>Site 6</b>	2.6	1.0	1.2	0.9	
9/8/2016	21XX N. Springfield Ave. <b>Site 1</b>	0.8	0.6	0.6	0.5	
11/2/2016	21XX W. Agatite Ave. <b>Site 1</b>	7.3	22	16	3.4	
1/18/2017	21XX W. Agatite Ave. <b>Site 1</b>	6.8	12	9.0	2.1	
	21XX W. Agatite Ave. <b>Site 1</b>	Customer was Non-Responsive				
9/7/2016	21XX N. Springfield Ave. <b>Site 2</b>	2.0	1.7	1.6	1.5	
1/11/2017	21XX N. Springfield Ave. <b>Site 2</b>	1.1	0.8	0.9	0.5	
2/8/2017	21XX N. Springfield Ave. <b>Site 2</b>	1.1	0.6	0.6	0.4	
3/13/2017	21XX N. Springfield Ave. <b>Site 2</b>	1.3	0.9	0.9	0.5	
4/4/2017	21XX N. Springfield Ave. <b>Site 2</b>	0.8	0.8	0.8	0.7	
5/3/2017	21XX N. Springfield Ave. <b>Site 2</b>	0.9	1.0	1.1	0.8	
6/7/2017	21XX N. Springfield Ave. <b>Site 2</b>	1.4	1.5	1.7	1.2	1.2
3/23/2017	21XX W. Grace St.	5.2	4.3	4.0	2.7	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
10/27/2016	21XX W. Sunnyside Ave. <b>Site 1</b>	4.3	5.5	6.4	3.8		
1/20/2017	21XX W. Sunnyside Ave. <b>Site 1</b>	3.0	4.2	7.9	5.0		
11/3/2016	21XX N. Maplewood Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
3/15/2017	21XX N. Maplewood Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
6/8/2017	21XX W. 54th Pl.	1.8	1.8	2.6	1.0		
10/27/2016	21XX N. Maplewood Ave. <b>Site 2</b>	4.3	5.6	5.3	4.1		
3/15/2017	21XX N. Maplewood Ave. <b>Site 2</b>	4.2	6.5	5.8	2.5		
10/27/2016	21XX W. Agatite Ave. <b>Site 2</b>	1.7	2.2	1.9	1.0	0.9	
1/18/2017	21XX W. Agatite Ave. <b>Site 2</b>	1.1	1.0	1.0	0.5		
9/8/2016	21XX N. Avers Ave.	6.8	10	11	7.4		
1/11/2017	21XX N. Avers Ave.	6.0	8.8	12	8.7		
11/3/2016	21XX N. Maplewood Ave. <b>Site 3</b>	2.2	0.7	0.7	0.6		
3/16/2017	21XX N. Maplewood Ave. <b>Site 3</b>	0.7	0.7	1.6	0.7		
10/27/2016	21XX W. Sunnyside Ave. <b>Site 2</b>	4.8	5.1	9.1	4.2		
1/20/2017	21XX W. Sunnyside Ave. <b>Site 2</b>	2.1	4.0	7.3	2.2		
10/27/2016	22XX N. Maplewood Ave.	3.2	11	7.3	3.2		
3/15/2017	22XX N. Maplewood Ave.	2.7	2.9	2.4	1.6		
4/12/2017	22XX N. Maplewood Ave.	4.2	10	6.2	2.1		
5/17/2017	22XX N. Maplewood Ave.	4.5	12	7.9	2.8		
6/21/2017	22XX N. Maplewood Ave.	3.8	13	8.5	3.4		
7/12/2017	22XX N. Maplewood Ave.	3.8	11	8.2	3.7		
8/16/2017	22XX N. Maplewood Ave.	5.3	11	8.0	4.5		
10/27/2016	23XX N. Maplewood Ave.	2.8	5.7	6.1	2.8		
3/21/2017	23XX N. Maplewood Ave.	2.7	7.2	7.8	1.5		
9/15/2016	23XX W. Jarvis Ave.	6.1	10	3.1	1.8		
12/21/2016	23XX W. Jarvis Ave.	5.3	5.3	7.4	1.2	1.3	
3/28/2017	24XX N. Talman Ave. Site 1	8.6	23	18	4.6		
7/18/2017	24XX N. Talman Ave. Site 1	14.0	26.0	20.0	7.7		
	24XX N. Talman Ave. Site 1	Customer Declined Further Testing					
3/22/2017	24XX N. Francisco Ave. <b>Site 1</b>	2.8	6.3	4.5	1.4		
7/11/2017	24XX N. Francisco Ave. <b>Site 1</b>	4.9	8.5	6.3	3.1		
8/23/2017	24XX N. Francisco Ave. <b>Site 1</b>	4.7	6.7	6.8	9.2		
4/3/2017	24XX N. Francisco AVE <b>Site 2</b>	7.0	37.0	37.0	4.9		
7/11/2017	24XX N. Francisco AVE <b>Site 2</b>	9.4	11.0	9.8	4.2	4.0	
	24XX N. Francisco AVE <b>Site 2</b>	Customer Declined Further Testing					
4/3/2017	24XX N. Francisco Ave. <b>Site 3</b>	<0.3	<0.3	<0.3	<0.3		
7/18/2017	24XX N. Francisco Ave. <b>Site 3</b>	<0.3	<0.3	<0.3	<0.3		
8/16/2017	24XX N. Francisco Ave. <b>Site 3</b>	<0.3	<0.3	<0.3	<0.3		
4/7/2017	24XX N. Talman Ave. Site 2	4.2	1.3	1.3	1.1		
4/6/2017	24XX N. Talman Ave. Site 3	5.1	11	9.7	1.9	1.9	
7/18/2017	24XX N. Talman Ave. Site 3	4.4	7.7	9.5	3.2		
3/16/2017	24XX N. Hamlin Ave.**	15	3.8	4.1	1.8		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
4/4/2017	24XX N. Hamlin Ave.**	See Follow-Up Sequential Sampling Table for Results					
4/18/2017	24XX N. Hamlin Ave.**	25	19	270	2.9		
4/6/2017	25XX N. Washtenaw Ave.	2.1	2.2	1.8	1.4		
7/19/2017	25XX N. Washtenaw Ave.	2.4	2.9	2.8	2.6		
4/19/2017	25XX N. Talman Ave.	0.8	0.7	0.9	0.5	0.5	
7/19/2017	25XX N. Talman Ave.	0.6	0.8	0.8	0.7		
10/19/2016	25XX N. Keeler Ave.	3.6	5.3	25	7.0		
11/2/2016	25XX N. Keeler Ave.	See Follow-Up Sequential Sampling Table for Results					
5/17/2017	25XX N. Keeler Ave.	4.2	6.0	20	3.2		
11/3/2016	25XX W. Shakespeare Ave.	2.8	2.5	4.4	1.6		
3/14/2017	25XX W. Shakespeare Ave.	1.7	1.3	1.7	0.9		
4/12/2017	25XX W. Shakespeare Ave.	1.6	1.6	2.7	1.1	1.2	
5/17/2017	25XX W. Shakespeare Ave.	1.6	1.4	1.9	1.4		
6/14/2017	25XX W. Shakespeare Ave.	1.4	1.4	1.5	1.3		
7/12/2017	25XX W. Shakespeare Ave.	1.7	1.2	1.7	1.7		
8/16/2017	25XX W. Shakespeare Ave.	1.8	1.7	1.9	1.9		
3/28/2017	26XX W. Homer St.	13	3.4	2.9	1.8		
4/12/2017	26XX W. Homer St.	4.1	7.0	7.0	2.0		
5/18/2017	26XX N. Whipple St.	1.9	5.5	4.3	1.8		
8/4/2017	26XX N. Whipple St.	1.9	4.9	3.9	2.2		
3/28/2017	26XX W. Altgeld St.	2.2	2.2	1.3	0.7		
7/21/2017	26XX W. Altgeld St.	4.2	4.4	2.4	1.5		
6/19/2017	26XX N. Drake Ave. Site 1	5.9	5.9	4.9	4.0		
4/10/2017	26XX W. Fullerton Ave.	6.8	2.8	3.6	1.6	1.6	
7/19/2017	26XX W. Fullerton Ave.	5.1	2.7	3.3	2.1		
9/30/2016	26XX S. Sacramento Ave.	2.2	0.9	0.7	0.5	0.6	
2/10/2017	26XX S. Sacramento Ave.	1.3	<0.3	<0.3	<0.3		
6/19/2017	26XX N. Drake Ave. Site 2^	4.6	22.0	16.0	5.6		
8/4/2017	26XX N. Drake Ave. Site 2^	See Follow-Up Sequential Sampling Table for Results					
6/19/2017	27XX N. Drake Ave. <b>Site 1</b>	14	10	10	3.1		
8/15/2017	27XX N. Drake Ave. <b>Site 1</b>	7.5	7.2	7.1	4.0		
5/18/2017	27XX N. Whipple St. <b>Site 2</b>	1.5	1.4	2.0	0.9		
8/11/2017	27XX N. Whipple St. <b>Site 2</b>	1.4	1.6	1.8	1.4		
5/19/2017	27XX N. Whipple St. <b>Site 3</b>	2.9	3.7	7.4	1.7		
8/4/2017	27XX N. Whipple St. <b>Site 3</b>	3.7	4.4	8.2	2.5		
5/18/2017	27XX N. Whipple St. <b>Site 4</b>	13	14	13	3.1		
8/4/2017	27XX N. Whipple St. <b>Site 4</b>	13	15	13	4.8		
	27XX N. Whipple St. <b>Site 4</b>	Customer Declined Further Testing					
5/19/2017	27XX N. Whipple St. <b>Site 5</b>	1.0	1.4	1.5	2.9		
8/25/2017	27XX N. Whipple St. <b>Site 5</b>	1.0	1.4	1.3	3.0		
5/19/2017	27XX N. Whipple St. <b>Site 6</b>	<0.3	<0.3	<0.3	<0.3		
8/3/2017	27XX N. Whipple St. <b>Site 6</b>	<0.3	<0.3	<0.3	0.5		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
6/19/2017	27XX N. Drake Ave. <b>Site 2</b>	2.0	0.9	0.8	1.5		
8/11/2017	27XX N. Drake Ave. <b>Site 2</b>	1.6	1.5	1.8	2.2		
5/30/2017	27XX N. Whipple St.	7.3	9.1	9.5	3.8		
8/8/2017	27XX N. Whipple St.	18	14	8.6	4.8	4.9	
	27XX N. Whipple St.	Customer Declined Further Testing					
9/30/2016	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
3/22/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
4/12/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
5/17/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
6/14/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
7/12/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
8/16/2017	28XX N. Christiana Ave. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
9/30/2016	28XX N. Christiana Ave. Site 2	19	15	13	8.4		
3/15/2017	28XX N. Christiana Ave. Site 2	12	16	12	4.6		
4/7/2017	28XX N. Christiana Ave. Site 2	See Follow-Up Sequential Sampling Table for Results					
10/25/2016	28XX W. 40th St.**	3.2	2.6	2.8	2.0		
2/24/2017	28XX W. 40th St.**	34	51	20	1.3		
3/3/2017	28XX W. 40th St.**	See Follow-Up Sequential Sampling Table for Results					
9/30/2016	28XX N. Christiana Ave. <b>Site 3</b>	5.6	11	11	5.2		
3/15/2017	28XX N. Christiana Ave. <b>Site 3</b>	5.7	8.0	8.1	2.7		
10/19/2016	29XX W. 40th St.	4.5	4.9	4.1	2.7		
2/24/2017	29XX W. 40th St.	3.5	2.2	1.9	1.4		
7/26/2017	29XX W. Wilson Ave.	9.3	13	12	3.9		
8/9/2017	30XX W. Wilson Ave.	1.7	3.8	6.1	1.8		
10/6/2016	30XX W. Diversey Ave. Site 1	7.8	8.3	12	5.3		
3/15/2017	30XX W. Diversey Ave. Site 1	5.5	7.0	8.0	3.0		
10/6/2016	30XX W. Diversey Ave. Site 2	<0.3	<0.3	<0.3	<0.3	<0.3	
3/14/2017	30XX W. Diversey Ave. Site 2	<0.3	<0.3	<0.3	<0.3		
4/12/2017	30XX W. Diversey Ave. Site 2	<0.3	<0.3	<0.3	<0.3	<0.3	
5/18/2017	30XX W. Diversey Ave. Site 2	<0.3	<0.3	<0.3	<0.3		
3/21/2017	30XX S. Homan Ave.	0.5	0.5	1.3	<0.3		
6/22/2017	30XX S. Homan Ave.	0.7	0.7	1.7	0.5		
4/5/2017	31XX N. Rutherford Ave.	2.4	3.9	3.8	1.3		
6/29/2017	31XX N. Ridgeway Ave. Site 1	3.8	6.1	6.0	3.9		
8/18/2017	31XX N. Ridgeway Ave. Site 1	5.5	13	11	5.4		
6/21/2017	31XX N. Ridgeway Ave. Site 2	7.9	6.2	3.4	5.6	5.3	
8/18/2017	31XX N. Ridgeway Ave. Site 2	6.8	8.8	6.1	9.5		
	31XX N. Ridgeway Ave. Site 2	Customer Declined Further Testing					
9/7/2016	32XX W Thomas St.	10	25	73	9.8		
8/2/2017	32XX W Thomas St.	See Follow-Up Sequential Sampling Table for Results					
4/10/2017	32XX N. Nagle Ave. <b>Site 1</b>	4.9	6.6	6.7	3.4		
6/27/2017	32XX N. Nagle Ave. <b>Site 1</b>	3.7	6.6	8.1	6.0		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
8/24/2017	32XX N. Nagle Ave. <b>Site 1</b>	4.6	7.1	8.2	6.0		
4/7/2017	32XX N. Nagle Ave. <b>Site 2</b>	0.5	0.6	0.6	0.5		
6/28/2017	32XX N. Nagle Ave. <b>Site 2</b>	2.0	2.4	2.2	1.3	1.3	
9/30/2016	32XX W. Diversey Ave.	4.5	6.2	4.5	2.0		
3/14/2017	32XX W. Diversey Ave.	1.4	1.8	2.4	1.6		
4/13/2017	32XX W. Diversey Ave.	1.4	1.7	2.2	1.4		
5/17/2017	32XX W. Diversey Ave.	3.1	6.1	3.3	1.2		
6/14/2017	32XX W. Diversey Ave.	1.7	4.6	7.1	1.6		
7/12/2017	32XX W. Diversey Ave.	2.1	2.0	2.1	1.7		
8/16/2017	32XX W. Diversey Ave.	2.9	6.9	5.9	2.1		
4/6/2017	32XX N. Nagle Ave. <b>Site 3</b>	2.9	6.1	7.3	2.2		
6/27/2017	32XX N. Nagle Ave. <b>Site 3</b>	4.5	5.6	11	7.6		
7/27/2017	32XX N. Nagle Ave. <b>Site 3</b>	7.2	5.0	7.1	5.1		
9/19/2017	32XX N. Nagle Ave. <b>Site 3</b>	See Follow-Up Sequential Sampling Table for Results					
3/23/2017	33XX N. Neva Ave.	1.7	3.0	3.0	0.6		
4/10/2017	33XX N. Neva Ave.	2.7	3.5	2.6	1.0		
8/2/2017	33XX W. 59th St.	1.2	1.2	1.4	0.9		
8/10/2017	33XX W. 59th St.	0.7	0.6	0.8	0.4		
8/15/2017	33XX W. 55th St.	<0.3	<0.3	<0.3	<0.3		
4/6/2017	33XX N. Nagle Ave.	2.0	2.2	2.2	1.0		
7/6/2017	34XX S. Marshfield Ave. Site 1	5.8	9.6	8.1	2.8	2.6	
10/25/2016	34XX W. 12th Pl. <b>Site 1</b>	<0.3	<0.3	<0.3	<0.3		
6/22/2017	34XX S. Marshfield Ave. Site 2	9.0	21	20	8.2		
7/10/2017	34XX S. Marshfield Ave. Site 2	See Follow-Up Sequential Sampling Table for Results					
6/2/2017	34XX N. Kostner Ave. <b>Site 1</b>	1.6	1.9	2.1	0.9		
6/2/2017	34XX N. Kostner Ave. <b>Site 2</b>	4.2	4.4	4.0	2.1		
10/25/2016	34XX W. 12th Pl. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
5/19/2017	34XX W. 12th Pl. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
6/29/2017	34XX W. 12th Pl. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
8/10/2017	34XX W. 12th Pl. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
6/28/2017	34XX S. Marshfield Ave. Site 3	7.7	6.4	5.4	3.2		
6/2/2017	34XX N. Kostner Ave. <b>Site 3</b>	3.3	5.8	8.5	1.7		
6/2/2017	34XX N. Kostner Ave. <b>Site 4</b>	10	2.0	9.9	0.9	0.9	
4/10/2017	35XX N. Nagle Ave. <b>Site 1</b>	1.8	4.3	3.2	0.9		
10/31/2016	35XX W. 12th Pl.	<0.3	<0.3	<0.3	<0.3		
5/25/2017	35XX W. 12th Pl.	<0.3	<0.3	<0.3	<0.3		
4/7/2017	35XX N. Nagle Ave. <b>Site 2</b>	<0.3	<0.3	0.3	<0.3		
6/27/2017	35XX N. Nagle Ave. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3	<0.3	
7/27/2017	35XX N. Nagle Ave. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
8/24/2017	35XX N. Nagle Ave. <b>Site 2</b>	<0.3	<0.3	<0.3	<0.3		
11/30/2016	35XX S. Paulina St.	0.8	<0.3	<0.3	<0.3		
3/23/2017	35XX S. Paulina St.	0.5	<0.3	<0.3	<0.3		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
10/26/2016	36XX W. 57th Pl. <b>Site 1</b>	2.8	4.9	7.5	2.1		
3/21/2017	36XX W. 57th Pl. <b>Site 1</b>	14	1.8	2.3	0.9		
10/26/2016	36XX W. 57th Pl. <b>Site 2</b>	2.1	3.5	2.9	1.9		
3/17/2017	36XX W. 57th Pl. <b>Site 2</b>	2.3	3.2	3.4	1.3		
4/13/2017	36XX W. 57th Pl. <b>Site 2</b>	2.7	3.5	3.6	1.4		
5/18/2017	36XX W. 57th Pl. <b>Site 2</b>	3.2	7.8	6.7	2.0		
6/22/2017	36XX W. 57th Pl. <b>Site 2</b>	4.0	5.6	9.0	2.9		
7/20/2017	36XX W. 57th Pl. <b>Site 2</b>	3.3	4.9	7.3	2.8		
8/17/2017	36XX W. 57th Pl. <b>Site 2</b>	5.4	9.0	8.7	3.6		
11/22/2016	36XX S. Paulina St. <b>Site 1</b>	2.9	0.8	0.7	0.6		
3/10/2017	36XX S. Paulina St. <b>Site 1</b>	1.1	0.5	0.5	0.4		
4/13/2017	36XX S. Paulina St. <b>Site 1</b>	3.3	0.7	0.7	0.5		
10/26/2016	36XX W. 57th Pl. <b>Site 3</b>	<0.3	<0.3	0.3	0.3		
11/22/2016	36XX S. Paulina St. <b>Site 2</b>	2.7	4.4	4.5	2.3		
3/10/2017	36XX S. Paulina St. <b>Site 2</b>	4.6	10	6.6	1.8		
4/13/2017	36XX S. Paulina St. <b>Site 2</b>	9.1	8.9	4.7	2.1		
5/23/2017	36XX S. Paulina St. <b>Site 2</b>	270	12	7.9	2.9		
6/7/2017	36XX S. Paulina St. <b>Site 2</b>	See Follow-Up Sequential Sampling Table for Results					
6/15/2017	36XX S. Paulina St. <b>Site 2</b>	4.1	4.7	4.8	3.1	3.2	
7/13/2017	36XX S. Paulina St. <b>Site 2</b>	3.8	6.2	7.4	3.0		
8/17/2017	36XX S. Paulina St. <b>Site 2</b>	4.0	4.6	4.4	3.5		
5/11/2017	36XX N. Drake Ave.	2.4	1.8	1.7	2.0		
8/24/2017	36XX N. Drake Ave.	2.0	4.0	4.2	2.4		
11/22/2016	36XX S. Paulina St. <b>Site 3</b>	2.2	3.1	2.1	1.8		
3/10/2017	36XX S. Paulina St. <b>Site 3</b>	3.3	3.4	2.3	1.8		
5/9/2017	36XX N. Whipple St.	1.2	2.1	2.4	1.1		
5/4/2017	37XX N. Whipple St. <b>Site 1</b>	2.1	1.9	1.5	1.0		
5/11/2017	37XX N. Drake Ave. <b>Site 1</b>	0.7	2.1	2.2	0.6		
8/24/2017	37XX N. Drake Ave. <b>Site 1</b>	1.2	2.0	2.2	1.2		
4/25/2017	37XX S. Michigan Ave.	3.5	5.3	4.8	1.5		
10/26/2016	37XX W. 57th Pl. <b>Site 1</b>	0.8	0.4	0.5	0.4		
3/17/2017	37XX W. 57th Pl. <b>Site 1</b>	0.7	1.1	0.5	0.5		
5/11/2017	37XX N. Drake Ave. <b>Site 2</b>	2.1	3.8	3.3	1.7		
8/24/2017	37XX N. Drake Ave. <b>Site 2</b>	4.4	6.0	4.9	4.4		
5/11/2017	37XX N. Drake Ave. <b>Site 3</b>	2.2	4.0	2.5	1.2		
8/24/2017	37XX N. Drake Ave. <b>Site 3</b>	2.9	6.3	4.3	2.5		
10/25/2016	37XX W. Ferdinand St.	5.9	5.5	4.8	3.3		
7/11/2017	37XX W. Ferdinand St.	6.1	5.2	4.4	3.1		
8/23/2017	37XX W. Ferdinand St.	4.3	4.4	4.1	3.6	3.6	
5/10/2017	37XX N. Drake Ave. <b>Site 4</b>	0.9	1.1	1.2	0.7	0.7	
8/24/2017	37XX N. Drake Ave. <b>Site 4</b>	1.6	2.3	2.4	2.0		
5/5/2017	37XX N. Whipple St. Site 1	3.7	20	13	2.2		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
5/27/2017	37XX N. Whipple St. Site 1	See Follow-Up Sequential Sampling Table for Results					
10/26/2016	37XX W. 57th Pl. <b>Site 2</b>	0.5	0.5	0.7	0.7		
3/17/2017	37XX W. 57th Pl. <b>Site 2</b>	0.5	0.5	0.7	0.4		
5/9/2017	37XX N. Whipple St. <b>Site 2</b>	2.2	2.0	2.0	1.4	1.2	
6/13/2017	37XX W. Eddy St.	1.3	2.3	2.0	0.8		
7/13/2017	37XX W. Eddy St.	1.4	3.1	2.2	0.9		
5/5/2017	37XX N. Whipple St. <b>Site 3</b>	1.1	1.9	1.5	0.3		
5/5/2017	37XX N. Whipple St. <b>Site 4</b>	2.7	3.9	4.7	1.6		
5/4/2017	37XX N. Whipple St. <b>Site 5</b>	5.8	7.0	6.9	2.6		
4/4/2017	38XX N. Kenneth Ave.	1.9	2.7	1.9	0.9		
4/25/2017	38XX N. Kenneth Ave.	2.3	3.0	3.3	1.1		
5/4/2017	38XX N. Whipple St. <b>Site 1</b>	0.8	1.2	1.4	0.5		
5/9/2017	38XX N. Whipple St. <b>Site 2</b>	4.5	0.9	0.7	0.4		
5/9/2017	38XX N. Whipple St. <b>Site 3</b>	13	26	23	5.6		
5/27/2017	38XX N. Whipple St. <b>Site 3</b>	See Follow-Up Sequential Sampling Table for Results					
8/10/2017	38XX N. Whipple St. <b>Site 3</b>	See Follow-Up Sequential Sampling Table for Results					
5/10/2017	38XX N. Drake Ave.	<0.3	<0.3	<0.3	<0.3		
8/23/2017	38XX N. Drake Ave.	<0.3	<0.3	<0.3	0.3		
5/30/2017	38XX N. Kedvale Ave.	5.4	4.7	8.8	2.2		
5/4/2017	39XX N. Whipple St. <b>Site 1</b>	12	33	25	5.1		
6/7/2017	39XX N. Whipple St. <b>Site 1</b>	See Follow-Up Sequential Sampling Table for Results					
5/5/2017	39XX N. Whipple St. <b>Site 2</b>	5.1	12	6.6	7.9		
5/5/2017	39XX N. Whipple St. <b>Site 3</b>	4.2	7.1	6.5	1.9		
11/2/2016	39XX W. 57th Pl.	1.6	3.3	3.3	1.6		
3/17/2017	39XX W. 57th Pl.	1.8	3.0	2.9	1.3		
7/7/2017	40XX W. Carroll Ave. Site 1	1.5	2.4	1.9	1.2		
7/6/2017	40XX W. Carroll Ave. Site 2	6.7	9.0	8.8	4.7		
6/2/2017	41XX N. Troy St.	1.2	2.5	2.5	1.7		
6/13/2017	41XX N. Troy St.	2.0	5.3	3.6	2.0		
9/29/2016	4XX W. 103rd St.	<0.3	<0.3	<0.3	<0.3		
1/10/2017	4XX W. 103rd St.	<0.3	<0.3	<0.3	<0.3		
9/29/2016	4XX W. 101st Pl. <b>Site 1</b>	1.3	2.5	2.3	1.1		
1/10/2017	4XX W. 101st Pl. <b>Site 1</b>	0.9	1.7	6.4	0.5		
2/8/2017	4XX W. 101st Pl. <b>Site 1</b>	1.0	2.3	1.8	0.6		
3/10/2017	4XX W. 101st Pl. <b>Site 1</b>	0.8	2.4	1.8	0.6		
4/4/2017	4XX W. 101st Pl. <b>Site 1</b>	1.0	1.9	1.8	0.6		
5/9/2017	4XX W. 101st Pl. <b>Site 1</b>	1.0	3.6	2.5	1.1		
6/6/2017	4XX W. 101st Pl. <b>Site 1</b>	1.2	3.6	2.5	1.1		
6/21/2017	42XX S. Indiana Ave.	0.9	1.3	1.7	1.5		
9/29/2016	4XX W. 101st Pl. <b>Site 2</b>	3.5	5.8	7.2	3.1		
1/10/2017	4XX W. 101st Pl. <b>Site 2</b>	5.3	6.9	6.2	6.8		
2/22/2017	42XX W. Hirsch St.	1.1	0.6	0.7	0.5		

all results are shown in PPB (Parts per Billion)



Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
3/1/2017	42XX W. Hirsch St.	1.9	0.7	0.7	0.6		
9/29/2016	4XX W. 101st Pl. <b>Site 3</b>	4.9	7.9	9.4	6.0		
1/11/2017	4XX W. 101st Pl. <b>Site 3</b>	6.2	8.4	7.6	2.8		
9/29/2016	4XX W. 101st Pl. <b>Site 4</b>	1.6	2.4	2.4	1.7		
1/11/2017	4XX W. 101st Pl. <b>Site 4</b>	2.6	2.3	4.2	1.6		
9/28/2016	4XX W. 101st Pl. <b>Site 5</b>	4.8	2.6	2.8	2.8		
4/26/2017	43XX N. Campbell Ave.	2.4	5.1	5.7	2.0		
5/10/2017	43XX N. Campbell Ave.	6.3	5.6	5.9	2.0		
9/28/2016	4XX W. 102nd St.	3.3	4.2	3.6	2.9		
1/19/2017	4XX W. 102nd St.	2.6	3.0	3.1	0.9	0.9	
8/8/2017	4XX W. 80th St.	1.9	2.0	2.2	1.4		
9/28/2016	4XX W. 101st Pl. <b>Site 6</b>	1.8	1.5	1.9	1.1		
1/10/2017	4XX W. 101st Pl. <b>Site 6</b>	1.4	0.8	0.6	0.5		
9/28/2016	4XX W. 101st Pl. <b>Site 7</b>	0.9	2.1	2.2	1.0		
1/10/2017	4XX W. 101st Pl. <b>Site 7</b>	1.0	1.9	5.3	0.6		
10/27/2016	44XX N. Hamilton Ave.	1.7	1.9	1.8	1.1		
1/18/2017	44XX N. Hamilton Ave.	1.0	2.2	3.2	1.2		
8/9/2017	44XX N. Sacramento Ave. Site 1	4.5	6.7	6.3	4.3		
9/20/2016	44XX N. Albany Ave. <b>Site 1</b>	8.7	13	13	2.7		
1/4/2017	44XX N. Albany Ave. <b>Site 1</b>	6.2	2.7	2.9	1.1		
6/29/2017	44XX S. Indiana Ave. Site 1	1.7	2.2	2.4	2.3		
7/25/2017	44XX N. Sacramento Ave. Site 2	4.2	3.9	3.6	3.5		
6/21/2017	44XX S. Indiana Ave. Site 2	4.1	5.0	5.5	3.5		
8/9/2017	44XX N. Sacramento Ave. Site 3	8.6	7.5	9.2	6.1		
9/20/2016	44XX N. Albany Ave. <b>Site 2</b>	1.9	2.0	2.1	1.2		
7/25/2017	44XX N. Whipple St. Site 1	12	7.9	4.0	6.0		
8/17/2017	44XX N. Sacramento Ave. Site 4	2.4	3.3	5.1	2.3	2.3	
9/30/2016	44XX N. Albany Ave. <b>Site 3</b>	0.5	0.6	0.6	0.4		
1/4/2017	44XX N. Albany Ave. <b>Site 3</b>	1.2	1.1	1.5	0.5	0.5	
7/25/2017	44XX N. Whipple St. Site 2	6.9	10	8.6	3.0		
8/9/2017	44XX N. Sacramento Ave. Site 5	1.4	2.0	2.0	2.3		
9/7/2016	44XX W. Grenshaw St.	8.2	6.5	3.5	2.3	2.3	
11/2/2016	44XX W. Grenshaw St.	8.7	7.1	2.4	1.4		
7/25/2017	45XX N. Sacramento Ave. Site 1	0.8	0.8	0.8	0.7		
9/20/2016	45XX N. Albany Ave. <b>Site 1</b>	4.1	11	12	2.5		
1/4/2017	45XX N. Albany Ave. <b>Site 1</b>	2.3	3.1	3.2	1.9		
9/20/2016	45XX N. Albany Ave. <b>Site 2</b>	12	20	18	5.1		
10/29/2016	45XX N. Albany Ave. <b>Site 2</b>	See Follow-Up Sequential Sampling Table for Results					
3/1/2017	45XX N. Albany Ave. <b>Site 2</b>	13	23	14	3.1		
4/19/2017	45XX N. Albany Ave. <b>Site 2</b>	34	43	29	4.4		
5/17/2017	45XX N. Albany Ave. <b>Site 2</b>	15	35	20	5.3		
6/14/2017	45XX N. Albany Ave. <b>Site 2</b>	14	25	18	5.0		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
7/12/2017	45XX N. Albany Ave. <b>Site 2</b>	16	28	20	5.9 J	12 J	
8/18/2017	45XX N. Albany Ave. <b>Site 2</b>	35	30	25	7.3		
7/26/2017	45XX N. Sacramento Ave. <b>Site 2</b>	2.5	7.1	7.4	2.3	2.2	
8/9/2017	45XX N. Whipple St. <b>Site 1</b>	1.0	1.1	1.0	0.5		
7/25/2017	45XX N. Whipple St. <b>Site 2</b>	2.9	2.3	1.9	1.2		
8/22/2017	45XX N. Sacramento Ave. <b>Site 3</b>	2.9	4.0	3.6	2.7		
8/4/2017	45XX N. Sacramento Ave. <b>Site 4</b>	1.7	3.6	6.4	1.8		
7/26/2017	45XX N. Whipple St. <b>Site 3</b>	<0.3	<0.3	<0.3	<0.3		
9/21/2016	45XX N. Albany Ave. <b>Site 3</b>	1.7	2.5	2.7	6.7 J	4.1 J	
1/11/2017	45XX N. Albany Ave. <b>Site 3</b>	1.6	3.4	3.1	2.8		
8/17/2017	45XX N. Sacramento Ave. <b>Site 5</b>	8.3	7.4	7.0	3.0		
7/26/2017	45XX N. Sacramento Ave. <b>Site 6</b>	2.6	3.5	3.8	3.6		
7/28/2017	47XX N. Sacramento Ave. <b>Site 1</b>	1.7	2.1	2.0	1.4		
7/25/2017	47XX N. Sacramento Ave. <b>Site 2</b>	5.6	8.2	8.0	3.5		
4/5/2017	48XX W. Eddy St.	1.2	1.3	1.3	0.5		
4/18/2017	48XX W. Eddy St.	2.0	0.8	1.0	0.7		
5/1/2017	49XX W. Cortez St.	9.0	3.0	2.7	2.4	2.4	
5/3/2017	49XX W. Superior St.	2.7	2.5	2.8	1.5		
4/24/2017	49XX W. Walton St.	0.4	0.5	0.6	0.3	0.3	
4/25/2017	50XX N. Neenah Ave.	2.8	3.7	5.1	0.8		
5/10/2017	50XX N. Neenah Ave.	3.8	5.0	6.3	1.1		
8/29/2016	52XX W. Congress Pkwy. <b>Site 1</b>	2.5	1.7	1.7	1.8		
8/31/2016	52XX W. Congress Pkwy. <b>Site 2</b>	5.5	5.3	5.1	3.9		
12/1/2016	52XX W. Congress Pkwy. <b>Site 2</b>	6.1	7.4	6.4	3.7		
8/30/2016	52XX W. Congress Pkwy. <b>Site 3</b>	2.7	1.2	1.1	0.8	0.8	
8/30/2016	52XX W. Congress Pkwy. <b>Site 4</b>	2.9	3.1	3.7	5.5		
3/16/2017	53XX N. Bernard St.**	3.8	3.3	3.0	2.6	2.6	
4/7/2017	53XX N. Bernard St.**	7.3	20	NS	16		
4/29/2017	53XX N. Bernard St.**	See Follow-Up Sequential Sampling Table for Results					
7/15/2017	53XX N. Bernard St.**	See Follow-Up Sequential Sampling Table for Results					
8/29/2016	53XX W. Congress Pkwy. <b>Site 1</b>	4.3	6.4	6.0	3.9		
12/1/2016	53XX W. Congress Pkwy. <b>Site 1</b>	7.9	4.0	5.0	3.2		
8/31/2016	53XX W. Congress Pkwy. <b>Site 2</b>	3.8	9.9	8.0	3.4		
12/14/2016	53XX W. Congress Pkwy. <b>Site 2</b>	3.0	4.2	3.0	1.8		
8/30/2016	53XX W. Congress Pkwy. <b>Site 3</b>	2.1	2.2	2.6	1.9		
12/1/2016	53XX W. Congress Pkwy. <b>Site 3</b>	2.5	2.6	2.6	1.9		
8/30/2016	53XX W. Congress Pkwy. <b>Site 4</b>	2.4	1.2	1.2	1.0		
12/2/2016	53XX W. Congress Pkwy. <b>Site 4</b>	4.1	3.4	3.4	2.1 J	1.3 J	
8/31/2016	54XX W. Congress Pkwy. <b>Site 1</b>	3.1	4.6	4.3	2.3		
12/2/2016	54XX W. Congress Pkwy. <b>Site 1</b>	2.9	3.9	3.6	2.7		
8/30/2016	54XX W. Congress Pkwy. <b>Site 2</b>	3.6	4.3	3.9	2.1		
12/2/2016	54XX W. Congress Pkwy. <b>Site 2</b>	4.4	4.7	6.0	2.1		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate
6/16/2017	54XX S. Seeley Ave.	<0.3	0.3	<0.3	<0.3	
8/29/2016	54XX W. Congress Pkwy. <b>Site 3</b>	0.5	0.5	0.5	0.3	
12/1/2016	54XX W. Congress Pkwy. <b>Site 3</b>	1.2	0.8	0.6	0.4	
2/1/2017	54XX W. Congress Pkwy. <b>Site 3</b>	0.9	0.9	0.4	0.3	0.4
3/1/2017	54XX W. Congress Pkwy. <b>Site 3</b>	0.9	0.7	0.4	0.4	
4/5/2017	54XX W. Congress Pkwy. <b>Site 3</b>	0.8	0.7	0.5	0.4	0.4
5/3/2017	54XX W. Congress Pkwy. <b>Site 3</b>	0.8	0.8	0.5	0.4	
6/7/2017	54XX W. Congress Pkwy. <b>Site 3</b>	0.8	0.8	0.6	0.5	
6/8/2017	54XX S. Hoyne Ave.	3.6	5.5	6.6	2.0	
8/30/2016	54XX W. Congress Pkwy. <b>Site 4</b>	0.7	2.2	2.6	0.6	
12/6/2016	54XX W. Congress Pkwy. <b>Site 4</b>	1.0	1.2	1.2	0.7	
8/31/2016	54XX W. Congress Pkwy. <b>Site 5</b>	1.9	0.4	0.4	0.4	
6/7/2017	54XX S. Seeley Ave.	1.8	1.6	1.6	0.9	
8/1/2017	56XX S. Christiana Ave. Site 1	1.0	1.3	1.0	0.8	
8/1/2017	56XX S. Christiana Ave. Site 2	5.0	3.9	4.1	3.5	
8/2/2017	56XX S. Christiana Ave. Site 3	5.3	1.5	1.5	2.7	
8/2/2017	56XX S. Christiana Ave. Site 4	3.1	4.0	7.9	5.2	
8/1/2017	57XX S. Christiana Ave. Site 1	0.8	0.5	0.6	0.7	
8/1/2017	57XX S. Christiana Ave. Site 2	4.8	5.0	7.0	2.6	2.5
8/25/2017	57XX S. Oak Park Ave.	2.3	1.7	1.8	1.6	
4/19/2017	57XX W. Midway Park <b>Site 1</b>	1.5	1.9	3.6	2.4	
4/26/2017	57XX W. Race Ave.	6.6	15	17	6.9	
5/17/2017	57XX W. Race Ave.	See Follow-Up Sequential Sampling Table for Results				
4/19/2017	57XX W. Midway Park <b>Site 2</b>	1.8	2.5	2.5	1.0	
8/1/2017	58XX S. Christiana Ave.	3.8	3.3	7.8	3.0	
8/22/2017	58XX S. Rutherford Ave.	2.8	12	12	2.2	
6/5/2017	59XX S. Campbell Ave.	0.8	0.6	1.0	0.6	
6/12/2017	60XX S. Campbell Ave. <b>Site 1</b>	1.0	0.9	0.7	0.5	
1/17/2017	60XX S. Moody Ave.	0.8	0.6	0.7	<0.3	<0.3
2/9/2017	60XX S. Moody Ave.	1.2	1.0	1.2	0.3	
6/6/2017	60XX S. Campbell Ave. <b>Site 2</b>	1.8	1.4	1.6	0.7	
4/13/2017	60XX N. Leader Ave.	5.3	8.2	12	2.2	
6/2/2017	60XX N. Leader Ave.	7.2	7.5	8.0	2.5	
6/5/2017	60XX S. Campbell Ave. <b>Site 3</b>	2.3	3.1	3.2	1.8	1.9
2/13/2017	60XX S. Kolin Ave.	0.7	0.6	0.5	0.4	
3/8/2017	60XX S. Kolin Ave.	0.5	<0.3	<0.3	<0.3	
6/5/2017	60XX S. Campbell Ave. <b>Site 4</b>	0.5	0.6	0.4	<0.3	
6/5/2017	60XX S. Campbell Ave. <b>Site 5</b>	1.4	2.0	2.7	1.6	
6/5/2017	60XX S. Campbell Ave. <b>Site 6</b>	3.1	3.9	3.3	2.1	
6/12/2017	61XXS. Campbell Ave.	2.3	1.4	1.9	1.0	
2/2/2017	61XX S. Moody Ave.	1.2	2.5	2.7	1.5	
2/23/2017	61XX S. Moody Ave.	1.7	4.4	11	1.5	

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
6/5/2017	62XX S. Campbell Ave.	0.6	<0.3	<0.3	<0.3		
5/4/2017	62XX N. Kirkwood Ave.	3.0	4.8	4.9	2.6		
5/31/2017	62XX N. Kirkwood Ave.	4.0	5.6	4.8	3.2		
4/4/2017	63XX S Kilpatrick Ave. <b>Site 1</b>	1.3	1.5	1.5	0.8		
6/28/2017	63XX S Kilpatrick Ave. <b>Site 1</b>	3.7	2.0	1.8	1.5		
8/3/2017	63XX S Kilpatrick Ave. <b>Site 1</b>	1.1	1.7	1.4	1.6		
8/17/2017	63XX S Kilpatrick Ave. <b>Site 1</b>	1.3	2.1	2.1	1.6		
4/5/2017	63XX S. Kilpatrick Ave. <b>Site 2</b>	1.8	2.5	3.0	1.4		
6/27/2017	63XX S. Kilpatrick Ave. <b>Site 2</b>	2.6	3.9	3.4	2.7		
7/20/2017	63XX S. Kilpatrick Ave. <b>Site 2</b>	2.6	4.5	5.2	2.8		
8/25/2017	63XX S. Kilpatrick Ave. <b>Site 2</b>	2.2	4.0	4.6	2.8		
4/11/2017	64XX S. Kilpatrick Ave.	4.5	13	13	2.6		
6/29/2017	64XX S. Kilpatrick Ave.	7.5	14	13	3.8		
5/31/2017	64XX S. Maplewood Ave.	1.5	1.4	1.5	0.9		
6/8/2017	64XX S. Maplewood Ave.	1.8	1.4	1.4	1.0		
4/5/2017	65XX S. Kilpatrick Ave. <b>Site 1</b>	1.4	1.8	1.8	0.9	0.9	
6/28/2017	65XX S. Kilpatrick Ave. <b>Site 1</b>	2.3	2.6	2.8	1.5		
4/17/2017	65XX S. Rockwell St.	1.5	2.3	2.7	1.0		
4/19/2017	65XX S. Maryland Ave.	1.1	2.3	1.8	0.9		
8/22/2017	65XX S. Maryland Ave.	1.3	2.0	2.8	1.5		
4/11/2017	65XX S. Kilpatrick Ave. <b>Site 2</b>	2.7	3.3	2.3	1.5		
6/22/2017	65XX S. Kilpatrick Ave. <b>Site 2</b>	3.4	8.0	13	3.4		
4/6/2017	65XX S. Kilpatrick Ave. <b>Site 3</b>	4.1	5.4	4.1	1.0		
6/27/2017	65XX S. Kilpatrick Ave. <b>Site 3</b>	3.6	7.2	4.6	1.9		
4/6/2017	66XX S. Kilpatrick Ave. <b>Site 1</b>	1.5	1.3	0.9	0.5		
6/22/2017	66XX S. Kilpatrick Ave. <b>Site 1</b>	1.9	1.1	1.0	0.9		
4/5/2017	66XX S. Kilpatrick Ave. <b>Site 2</b>	1.8	1.7	1.9	1.6		
6/27/2017	66XX S. Kilpatrick Ave. <b>Site 2</b>	2.8	4.9	5.4	3.2		
4/6/2017	66XX S. Kilpatrick Ave. <b>Site 3</b>	2.0	4.3	2.3	0.8		
6/22/2017	66XX S. Kilpatrick Ave. <b>Site 3</b>	4.0	5.8	8.4	5.0		
7/20/2017	66XX S. Kilpatrick Ave. <b>Site 3</b>	4.8	8.3	47	3.8		
8/25/2017	66XX S. Kilpatrick Ave. <b>Site 3</b>	6.5	6.2	9.5	2.6		
	66XX S. Kilpatrick Ave. <b>Site 3</b>	Customer Declined Further Testing					
4/5/2017	66XX S. Kilpatrick Ave. <b>Site 4</b>	2.6	3.8	7.5	1.8		
6/28/2017	66XX S. Kilpatrick Ave. <b>Site 4</b>	4.0	5.6	8.1	3.8		
7/28/2017	66XX S. Kilpatrick Ave. <b>Site 4</b>	2.6	3.0	4.6	2.5		
8/18/2017	66XX S. Kilpatrick Ave. <b>Site 4</b>	3.0	5.4	8.2	3.7		
4/4/2017	66XX S. Kilpatrick Ave. <b>Site 5</b>	8.0	9.4	10	2.5		
6/27/2017	66XX S. Kilpatrick Ave. <b>Site 5</b>	10	11	12	8.3		
1/17/2017	67XX W. 64th St.	3.5	2.6	3.1	0.9		
2/13/2017	67XX W. 64th St.	8.0	3.3	3.0	1.1		
2/8/2017	67XX N. Jean Ave.	2.9	7.7	9.1	1.7		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
5/16/2017	67XX N. Jean Ave.	6.0	19	23	2.9		
6/9/2017	67XX N. Jean Ave.	See Follow-Up Sequential Sampling Table for Results					
6/13/2017	67XX N. Jean Ave.	2.6	12	15	2.6		
7/18/2017	67XX N. Jean Ave.	3.5	10	17	3.3		
8/18/2017	67XX N. Jean Ave.	5.4	16	23	3.7		
7/28/2017	6824 S. Normal Blvd.	3.1	5.8	4.6	3.3		
10/26/2016	70XX S. Perry Ave.	3.9	5.7	5.0	2.4	2.5	
4/11/2017	71XX S. Honore St. <b>Site 1</b>	2.2	4.6	6.5	1.0		
4/11/2017	71XX S. Honore St. <b>Site 2</b>	0.9	0.9	1.0	0.5		
5/31/2017	71XX S. Rockwell St.	2.7	3.1	3.0	2.4		
4/11/2017	71XX S. Honore St. <b>Site 3</b>	1.0	1.2	0.7	0.5		
9/15/2016	72XX N. Claremont Ave.	2.6	5.3	5.5	3.7		
12/21/2016	72XX N. Claremont Ave.	2.5	6.8	8.1	1.8		
5/31/2017	72XX S. Rockwell St.	1.4	2.9	3.4	1.4		
4/25/2017	XX E. 37th Pl.	4.1	5.8	3.5	0.8		
4/13/2017	73XX S. Honore St. <b>Site 1</b>	6.2	9.0	10	5.1		
4/11/2017	73XX S. Honore St. <b>Site 2</b>	3.1	4.5	4.0	1.3	1.3	
5/31/2017	73XX S. Rockwell St. <b>Site 1</b>	2.9	2.3	2.9	2.1		
6/1/2017	73XX S. Rockwell St. <b>Site 2</b>	7.2	5.8	6.0	2.8		
1/17/2017	74XX S. Calumet Ave.	3.6	3.5	4.0	0.6		
2/14/2017	74XX S. Calumet Ave.	3.2	2.8	2.1	0.5	0.4	
8/24/2016	80XX S. Avalon Ave.	4.0	3.8	3.7	2.4		
12/16/2016	80XX S. Avalon Ave.	2.9	2.0	2.0	1.0		
1/31/2017	80XX S. Avalon Ave.	3.6	4.0	4.0	1.1		
2/21/2017	80XX S. Avalon Ave.	3.2	2.4	2.2	1.0		
3/21/2017	80XX S. Avalon Ave.	2.7	2.1	2.1	1.1		
4/18/2017	80XX S. Avalon Ave.	2.7	2.7	2.4	1.2		
5/16/2017	80XX S. Avalon Ave.	3.6	5.3	4.3	2.1		
2/2/2017	81XX S. Champlain Ave.	7.4	7.1	8.0	2.9		
2/23/2017	81XX S. Champlain Ave.	10	4.9	7.6	3.9		
8/25/2016	81XX S. Avalon Ave.	1.1	1.4	1.3	1.1		
12/15/2016	81XX S. Avalon Ave.	0.7	1.1	1.0	0.4		
8/25/2016	82XX S. Avalon Ave. <b>Site 1</b>	2.1	1.0	0.7	0.7		
12/15/2016	82XX S. Avalon Ave. <b>Site 1</b>	1.2	1.3	0.8	0.7		
4/4/2017	82XX S. Kingston Ave.**	9.5	3.6	3.8	2.3		
4/18/2017	82XX S. Kingston Ave.**	7.5	7.5	28	3.0	2.8	
5/5/2017	82XX S. Kingston Ave.**	See Follow-Up Sequential Sampling Table for Results					
8/1/2017	82XX S. Kingston Ave.**	See Follow-Up Sequential Sampling Table for Results					
8/24/2016	82XX S. Avalon Ave. <b>Site 2</b>	1.4	7.3	5.0	1.2		
12/15/2016	82XX S. Avalon Ave. <b>Site 2</b>	1.9	3.2	3.4	1.0		
8/25/2016	82XX S. Avalon Ave. <b>Site 3</b>	7.1	14	13	3.4		
12/16/2016	82XX S. Avalon Ave. <b>Site 3</b>	6.0	7.7	6.2	1.4		

all results are shown in PPB (Parts per Billion)

Date Sampled	Address	1st Draw	4th Draw	6th Draw	5 Minute Flush	5 Minute Flush Duplicate	
1/31/2017	82XX S. Avalon Ave. <b>Site 3</b>	4.9	8.3	7.4	1.3		
2/21/2017	82XX S. Avalon Ave. <b>Site 3</b>	5.9	8.9	5.4	1.3		
3/21/2017	82XX S. Avalon Ave. <b>Site 3</b>	4.8	11	10	1.4		
4/18/2017	82XX S. Avalon Ave. <b>Site 3</b>	5.1	7.1	5.9	1.5		
5/16/2017	82XX S. Avalon Ave. <b>Site 3</b>	7.9	11	10	2.3		
5/3/2017	8XX N. Lavergne Ave.	<0.3	.	<0.3	<0.3		
7/27/2017	89XX S. Hamilton Ave. ^	4.9	.	3.8	18		
9/9/2017	89XX S. Hamilton Ave. ^	See Follow-Up Sequential Sampling Table for Results					
7/27/2017	90XX S. Hamilton Ave. Site 1	2.6	3.9	4.5	2.0		
7/27/2017	90XX S. Hamilton Ave. Site 2	3.7	5.1	4.8	3.5		
7/27/2017	91XX S. Hamilton Ave.	3.4	4.2	3.0	2.0		
5/1/2017	9XX N. Lavergne Ave. Site 1	2.3	1.9	2.8	1.8		
4/24/2017	9XX N. Lavergne Ave. Site 2	4.3	2.3	2.0	1.3		

\*Water pressure so low, couldn't take sample at 6th liter

\*\*Samples did not meet study specifications

^Unable to obtain full sample set

The results listed on this page are from residential homes in Chicago that have volunteered to have their water tested for lead as part of a research study. The data that is shown below is quality controlled. The study is ongoing, and the results below are a small portion of the large sample population necessary for statistical evaluation. The data below will be further reviewed prior to inclusion in statistical evaluation. The results are anonymized to the block level, so the complete address of each home is not posted. In cases where a sample tests over 15 parts per billion (the action limit set by the EPA), the Department of Water Management will contact the homeowner to discuss the results and schedule a time to resample the water and inspect the home's plumbing and electrical wiring to better evaluate possible causes. All results are shown in PPB (Parts per Billion). In cases where multiple homes on the same block have results, the location is further amended as "Site 1", "Site 2", etc.

Follow-Up Sequential Sampling		Sequential Draws										Timed Draws				
Date Sampled	Address	1st Draw	2nd Draw	3rd Draw	4th Draw	5th Draw	6th Draw	7th Draw	8th Draw	9th Draw	10th Draw	3 Minute	5 Minute	7 Minute	10 Minute	15 Minute
10/8/2016	103XX S. Racine Ave.	2.2	2.3	4.1	3.7	9.4	15.4	11.5	10.5	11.2	10.2	8.4	4.4			
4/4/2017	24XX N. Hamlin Ave.**	23.0	5.2	4.3	4.6	4.5	3.5	9.7	8.7	8.6	6.8	3.9	3.3			
11/2/2016	25XX N. Keeler Ave.	5.1	5.7	3.1	2.7	6.3	11.9	25.0	24.0	12.4	5.7	4.2	3.2			
4/7/2017	28XX N. Christiana Ave. Site 2	10.4	15.6	14.2	11.9	11.1	10.2	9.5	8.5	8.4	6.5	5.3	4.9	4.6	4.5	4.3
3/3/2017	28XX W. 40th St**	4.1	3.2	3.2	2.4	3.4	3.9	2.6	4.0	2.7	5.1	3.1	1.4			
8/2/2017	32XX W Thomas St.	9.6	9.5	9.2	9.5	19.1	43.9	35.3	24.9	23.1	22.4	23.2	8.8	8.4	7.1	6.9
7/10/2017	34XX S. Marshfield Ave. Site 2	24.0	28.8	58.2	29.0	21.7	20.3	20.1	13.1	10.5	9.8	9.5	8.9	8.8	8.3	8.0
6/7/2017	36XX S. Paulina St. Site 2	6.2	2.6	4.8	2.3	2.3	2.6	4.3	2.2	2.1	2.1	2.0	1.9			
5/27/2017	37XX N. Whipple St. Site 1	5.2	6.1	5.1	7.1	6.1	4.5	5.0	3.6	3.5	2.2	2.0	1.6			
5/27/2017	38XX N. Whipple St. Site 3	13.9	23.1	39.8	26.7	27.0	25.3	24.9	24.7	33.1	17.4	6.2	5.3			
8/10/2017	38XX N. Whipple St. Site 3	14.3	21.7	28.2	29.6	30.5	30.0	33.6	38.6	34.8	32.1	10.4	8.3	8.0	7.9	7.6
6/7/2017	39XX N. Whipple St. Site 1	177.0	93.4	123.0	110.0	84.1	70.9	41.5	22.7	42.5	52.9	9.9	7.8			
10/29/2016	45XX N. Albany Ave. Site 2	16.3	24.3	34.7	30.5	29.9	26.0	21.6	23.9	24.5	21.4	4.8	4.4			
4/29/2017	53XX N. Bernard St.**	4.0	10.7	17.7	15.5	14.4	13.8	12.6	9.5	6.0	3.2	3.1	2.0			
7/15/2017	53XX N. Bernard St.**	7.6	8.4	8.3	8.4	8.5	8.5	8.1	7.4	7.0	6.8	6.8	5.3			
5/17/2017	57XX W. Race Ave.	6.1	7.7	11.7	10.1	10.0	10.7	11.0	9.7	12.3	6.0	5.2	4.8			
6/9/2017	67XX N. Jean Ave.	2.6	3.3	4.2	10.5	13.9	14.9	17.6	12.7	19.9	21.6	4.2	2.0			
5/5/2017	82XX S. Kingston Ave.	5.5	4.0	3.1	12.5	26.9	14.2	13.2	30.9	20.6	5.1	9.5	2.8			
8/1/2017	82XX S. Kingston Ave.	13.1	3.0	3.1	3.8	6.5	8.3	11.6	9.7	9.5	14.4	8.2	3.1	3.2	2.9	2.7
9/6/2017	107XX S. Ave. N	57.1	28.7	25.1	22.1	20.2	18.9	16.8	17.6	15.4	14.1	5.3	4.3			
8/4/2017	26XX N. Drake Ave. Site 2	1.6	2.1	1.7	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
9/9/2017	89XX S. Hamilton Ave.	5.1	6.4	6.7	8.0	7.3	6.7	6.5	6.6	6.5	6.2	5.5	5.0			
9/19/2017	32XX N. Nagle Ave. Site 3	6.3	8.1	7.5	8.4	11.2	14.1	15.7	15.6			15.2	27.0	5.0	4.2	4.0

\*\*Samples did not meet study specifications